



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board

San Diego Region



Arnold Schwarzenegger
Governor

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

May 5, 2010

In reply refer to:
248439:chenning

Ms. Milica Kaludjerski
Department of Public Works
County of San Diego
5555 Overland Ave., Suite 2188
San Diego, CA 92123-1295

Dear Ms. Kaludjerski:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR THE
PINE VALLEY WATER POLLUTION CONTROL FACILITY**


This letter is to notify the County of San Diego that in reviewing the April–June 2009, July–September 2009, October–December 2009, and January–March 2010 quarterly; April–September and July–December 2009 semi-annual; and 2009 annual monitoring reports, the California Regional Water Quality Control Board, San Diego Region identified four violations of Order No. 94-161. The following describes the violations:

The County of San Diego exceeded the 12-month average discharge specification for total dissolved solids (TDS), established at 750 milligrams per liter (mg/L), in July 2009, October 2009, December 2009, and March 2010 with reported values of 800, 898, 850 and 827.5 mg/L, respectively.

In the future, please accurately identify all reports and submit them by their due date. The April–September 2009 semi-annual report should have been entitled the January–June 2009 semi-annual report. The April–September 2009 semi-annual report was received October 28, 2009; the January–June 2009 semi-annual report should have been submitted on July 30, 2009. However, the information required to be submitted in the semi-annual report was contained in the January–March 2009 quarterly report, which was submitted prior to July 30, 2009.

The next monitoring reports required to be submitted are the January–June 2010 semi-annual and April–June 2010 quarterly monitoring reports due on July 30, 2010.


California Environmental Protection Agency



04060001

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ms. Cathryn Henning of my staff at (858) 636-3161 or at chenning@waterboards.ca.gov.

Sincerely,



Robert Morris, P.E.
Senior Water Resource Control Engineer

REP:clh

| | |
|-----------------------|---------------|
| Regulatory Measure ID | 142494 |
| Place ID | 248439 |
| Enforcement ID | 374042 |
| Violation ID | 869199-869202 |